



ठाणे महानगरपालिका

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

प्रदूषण नियंत्रण कक्ष

POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas ,Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 2118

Sample No. : R777

Date : 3 November 2025

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S Arunodaya Public School

Address : Vijay Park, Kasarvadavli, GB Road, Thane (W)

E_mail ID : principalapsthane@gmail.com ; infoapsthane@gmail.com

Date of receiving Sample : 31 October 2025

Sample Collected by : Prathamesh Sangar

Type of Water Sample : Storage Drinking (4th Sample)

Parameters	Results	Limits as per IS 10500
pH	7.60	6.5 - 8.5
Free Residual Chlorine	0.4	1 ppm
Turbidity	2.0	5 NTU
Chloride	50.0	250 mg/L
Total Hardness	115.0	300 mg/L
Total Coilform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

3-Nov-25

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

3-Nov-25

For Nirmitee N. Salgaonkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (4th Sample) Water sample received to our Vakratunda Laboratory on 31/10/2025. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. 6380/- vide Receipt No.TMC/HQ/PLC/000099/24-25 dated 16.07.2024

This Report Is Digitally Signed And Approved.